

CALIBRATION OF:
8" ORIFICE
SERIAL NUMBER: 1023

FOR
BELL TECHNOLOGIES, LLC
PURCHASE ORDER NUMBER: 1006-REV 0
JANUARY 2020 - REPORT NO. 2201BEL001-R1

CERTIFIED BY
Philip Stacy



All Client supplied information and calibration results are considered proprietary and confidential to the Client. If a third party is a witness during calibrations or if the Client requests transmittal of data to a third party, Alden considers that the Client has waived confidentiality for the Witness.

In the event the Client distributes any report issued by Alden outside its own organization, such report shall be used in its entirety, unless Alden approves a summary or abridgment for distribution.

No advertising or publicity containing any reference to Alden or any employee, either directly or by implication, shall be made use of by Client without Alden's written approval.



INTRODUCTION

Meters referenced within this report were calibrated at Alden Research Laboratory, Inc. (Alden). Alden's standard test procedures in QMSM-01 Revision 9 were used for testing. Flow meter performance is presented in both tabular and graphical format.

FLOW ELEMENT INSTALLATION

Each meter under test (MUT) was installed in one of the four test lines in the Allen High Reynolds Number Facility, which is shown in plan view in Figure 1. One or two 300 horsepower centrifugal pumps, which are used singularly or in parallel, provide a maximum head of about 130 feet at a flow of about 44 ft³/second in Line 2. A separate pump provides a maximum head of about 300 feet at a flow of about 12 ft³/s in Lines 3 and 4. Water is provided from a heated 180,000 gallon sump under the test floor. The Gravimetric Method was used to measure flow.

The detailed piping arrangement, immediately upstream and downstream of the flow element, including all significant fittings and pipe lengths, is shown in the included figures. Careful attention was given to align the flow element with the test line piping, and to assure no gaskets between flanged sections protruded into the flow. Vents were provided at critical locations of the test line to purge the system of air.

TEST PROCEDURE

After checking the installation, water was introduced into the system to equalize line and primary element temperature to water temperature. The downstream control valve was then closed and vent valves in the test line were opened to remove air from the system.

Prior to the test run, the control valve was set to produce the desired flow, while the flow was directed to waste. Sufficient time was allowed to stabilize both the flow and the instrument readings, after which the weigh tank discharge valve was closed and the weigh tank scale indicator and the electric timer were both zeroed. To begin the test run, flow was diverted into the weigh tank, which automatically started the timer.



At the start of the water collection a computer based data acquisition system was activated to read the meter output, such that the meter output was averaged while the weigh tank was filling. At the end of the run, flow was diverted away from the weigh tank and the timer and data acquisition system were stopped to terminate the test run. The weight of water in the tank, elapsed time, water temperature, and average meter output were recorded on a data sheet. The data were entered into the computer to determine the flow and the results were plotted so that each test run was evaluated before the next run began. The control valve was then adjusted to the next flow and the procedure repeated.

FLOW MEASUREMENT METHOD

Flow was measured by the gravimetric method using a tank mounted on scales having capacities of 1,000, 10,000 and 100,000 pounds with resolution of 0.1, 0.2 and 1.0 pound, respectively. Alden's flow meter calibrations using the gravimetric flow measurement method comply with ASME/ANSI MFC-9M-1988 Measurement of Liquid Flow in Closed Conduits by Weighing Method. Water passing through the flow element was diverted into the tank with a hydraulically operated knife edge passing through a rectangular jet produced by a diverter head box. A Hewlett-Packard 10 MHz Frequency Counter with a resolution 0.001 sec was started upon flow diversion into the tank by an optical switch, which is positioned at the center of the jet. The timer was stopped upon flow diversion back to waste and the elapsed diversion time was recorded. An RTD thermometer measured water temperature to allow calculation of water density. Volumetric flow was calculated by Equation (1).

$$q_a = \frac{W}{T\rho_w B_c} \quad (1)$$

where

| | | |
|----------|---|---|
| q_a | = | actual flow, ft ³ /sec |
| W | = | mass of water collected, lb _m |
| T | = | time, sec |
| ρ_w | = | water density, lb _m /ft ³ |
| B_c | = | buoyancy correction, $1 - \rho_a / \rho_w$ |



The buoyancy correction includes air density calculated by perfect gas laws with the standard barometric pressure, a relative humidity of 75%, and measured air temperature. The weigh tank is periodically calibrated to full scale using 10,000 lbm of cast iron weights, whose calibration is traceable to NIST. Flow calculations are computerized to assure consistency. Weigh tank calibration data and water density as a function of temperature, are stored on disk file. Data were recorded manually and on disk file for later review and reporting.

DISCHARGE COEFFICIENT CALCULATIONS

If applicable, the MUT discharge coefficient, C , is defined by Equation (2) and plotted versus pipe or throat Reynolds number. Calculations of the discharge coefficient of differential producing flow meters are in accordance with ASME/ANSI MFC-3M-2004 Measurement of Fluid Flow in Pipes Using Orifice, Nozzle and Venturi, and ASME 19.5-2004 Flow Measurement. The discharge coefficient relates the theoretical flow to the actual flow.

$$C = \frac{q_a}{q_{th}} = \frac{q_a}{F_a K_M \sqrt{\Delta h}} \quad (2)$$

where

| | | |
|------------|---|---|
| C | = | discharge coefficient, dimensionless |
| q_{th} | = | theoretical flow, ft ³ /sec |
| F_a | = | thermal expansion factor, dimensionless |
| Δh | = | differential head, ft at line temperature |
| K_M | = | meter constant, ft ^{2.5} /sec |

The theoretical proportionality constant, K_M , between flow and square root of differential head is a function of the meter throat area, the ratio of throat to pipe diameter, and the local gravitational constant, as defined by Equation (3).

$$K_M = \frac{a_t \sqrt{2g_l}}{\sqrt{1-\beta^4}} \quad (3)$$



where a_t = throat area, $\pi d^2 / 4$, ft²
 d = throat diameter, ft
 g_l = local gravitational constant, 32.1625 ft/sec² at Alden
 β = ratio of throat to pipe diameter, d/D , dimensionless
 D = pipe diameter, ft

The effect of fluid properties, viscosity and density, on the discharge coefficient is determined by Reynolds number, the ratio of inertia to viscous forces. Pipe Reynolds number, R_D , or throat Reynolds number, R_d is determined by Equation (4).

$$R_D = \frac{q_a D}{a_p \gamma} \quad (R_d = \frac{q_a d}{a_t \gamma}) \quad (4)$$

where a_p = pipe area, $\pi D^2 / 4$, ft², (throat area $a_t = \pi d^2 / 4$, ft²)
 γ = kinematic viscosity, ft²/sec

HEAD LOSS CALCULATION

If applicable, to determine the unrecoverable head loss if the MUT, pairs of pressure taps were installed approximately two pipe diameters upstream and ten pipe diameters downstream of the flow meter. This gross head loss was measured during the determination of the discharge coefficient. Thereafter, the flow meter was removed from the test line and the head loss due to the pipe was measured over a similar range of flows to determine the unique coefficients of k_p and n in Equation 5 below.

$$k_p = \frac{\Delta H_{fric}}{q_a^n} \quad (5)$$

Where: k_p = friction loss coefficient, ft^{5/2}/s
 ΔH_{fric} = pipe friction loss, feet



q_a = actual flow, ft³/sec

n = Coefficient

Equivalent pipe losses were calculated by solving Equation 5 for pipe loss, ΔH_{fric} :

$$\Delta H_{fric} = k_p q_a^n \quad (6)$$

Pipe losses, characterized by Equation 6 were subtracted from the measured gross loss for the calculation of meter unrecoverable head loss as shown by Equation (7). The meter unrecoverable head loss is presented as a percent of the meter differential head.

$$\Delta H_{net\ meter} = \Delta H_{static} - \Delta H_{fric} \quad (7)$$

where: ΔH_{net} = meter unrecoverable head loss, feet

ΔH_{static} = measured static head difference, feet

FLOW METER SIGNAL RECORDING

The MUT indicated flow was recorded at the end of each weigh tank run. The method employed was according to the requirements of each meter and may include; gating the meter to totalize collected gallons, interrogating a mA output, totalized pulses, or manual reading of the MUT display. For MUT producing a differential pressure, the secondary element, which converts the primary element signal into engineering units, was one of several "Smart" differential pressure transmitters having a range of 250 inches of water column, 1,000 inches of water column and 100 psi. Each transmitter was calibrated with a pneumatic or a hydraulic dead weight tester having an accuracy of 0.02% of reading. Transmitter signals were recorded by a PC based data acquisition system having a 16 bit A to D board. Transmitter calibrations were conducted with the PC system such that an end to end calibration was achieved. Transmitter output was read simultaneously with the diversion of flow into the weigh tank at a rate of about 34 Hz for each test run (flow) and averaged to obtain a precise differential head. Average transmitter reading was converted to feet of flowing water using a linear regression analysis of the calibration data and line water temperatures to calculate appropriate specific weight.



TEST RESULTS

The results are presented in tabular and graphical format. The calculated flow, meter signal and meter performance are listed in the table(s) in the following pages.

Analysis indicates that the flow measurement uncertainty is within 0.25% of the true value for each test run. Calibrations of the test instrumentation (temperature, time, weight, and length measurements) are traceable to the National Institute of Standards and Technology (formerly the National Bureau of Standards) and Alden's Quality Assurance Program is designed to meet ANSI/NCSL Z540-1-1994 "Calibration Laboratories and Test Equipment-General Requirements" (supercedes MIL-STD-45662A).





Figure 1
Allen High Reynolds Number Facility Test Lines 1, 2, 3 and 4



THIS PAGE INTENTIONALLY BLANK

Plan View Allen facility Line 3



BELL TECHNOLOGIES, LLC
Purchase Order Number: 1006-REV 0
8" ORIFICE
Serial Number: 1023
January 8, 2020

BELL TECHNOLOGIES, LLC

Purchase Order Number: 1006-REV 0
 8" ORIFICE
 Serial Number: 1023

CALIBRATION
 DATE: January 8, 2020
 PIPE DIAMETER = 7.9810
 THROAT DIAMETER = 5.5872


| Run # | Line Temp Deg F | Air Temp Deg F | Net Weight lb. | Run Duration secs. | Output [see note] | Flow GPM | H Line FT H2O | Pipe Rey. # x 10 ⁶ | Coef |
|-------|-----------------|----------------|----------------|--------------------|-------------------|----------|---------------|-------------------------------|--------|
| 1 | 107 | 73 | 63635 | 122.498 | 8.018~ | 3771. | 63.151 | 2.3341 | 0.6744 |
| 2 | 107 | 73 | 59224 | 124.049 | 7.083~ | 3465. | 53.331 | 2.1447 | 0.6745 |
| 3 | 107 | 72 | 63235 | 145.233 | 6.226~ | 3160. | 44.335 | 1.9555 | 0.6747 |
| 4 | 107 | 72 | 48710 | 123.723 | 5.451~ | 2858. | 36.201 | 1.7677 | 0.6751 |
| 5 | 107 | 72 | 47920 | 136.189 | 4.753~ | 2554. | 28.876 | 1.5795 | 0.6756 |
| 6 | 107 | 73 | 44242 | 142.866 | 4.131~ | 2248. | 22.349 | 1.3900 | 0.6758 |
| 7 | 107 | 72 | 32576 | 121.831 | 8.360~ | 1941. | 16.636 | 1.1999 | 0.6764 |
| 8 | 107 | 72 | 27676 | 122.850 | 6.513~ | 1635. | 11.809 | 1.0107 | 0.6764 |
| 9 | 107 | 73 | 22333 | 121.668 | 4.990~ | 1332. | 7.827 | 0.8231 | 0.6769 |
| 10 | 107 | 73 | 21512 | 152.194 | 3.769~ | 1026. | 4.637 | 0.6336 | 0.6772 |
| 11 | 107 | 73 | 20755 | 207.970 | 2.878~ | 724.4 | 2.308 | 0.4472 | 0.6777 |
| 12 | 107 | 73 | 69348 | 123.534 | 9.032~ | 4075. | 73.790 | 2.5262 | 0.6743 |

~ dp transmitter volts

The data reported on herein was obtained by measuring equipment the calibration of which is traceable to NIST, following the installation and test procedures referenced in this report, resulting in a flow measurement uncertainty of +/- 0.25% or less.

CALIBRATED BY: DAV

CERTIFIED BY: 



| | |
|--|-----------|
| $q_a = C F_a K_M \sqrt{\Delta h}$ | |
| q_a = Actual Flow (ft ³ /sec) C = Discharge Coefficient (Dimensionless) Δh = Pressure Differential (Feet of Water at Run Temperature) | |
| K_M = Meter Constant = $\frac{a\sqrt{2g}}{\sqrt{1 - \beta^4}}$ | = 1.5666 |
| F_a = Average Thermal Expansion Factor | = 1.0007 |
| a = Throat Area (ft ²) | = 0.1703 |
| g = Local Acceleration of Gravity (ft/sec ²) | = 32.1625 |
| β = Ratio of Throat to Pipe Diameter (Dimensionless) | = 0.7001 |
| Pipe Diameter (Inches) | = 7.9810 |
| Throat Diameter (Inches) | = 5.5872 |
| Dimensions By: BELL TECHNOLOGIES, LLC | |

BELL TECHNOLOGIES, LLC
 Purchase Order Number: 1006-REV 0
 8" ORIFICE
 Serial Number: 1023
 January 8, 2020

Certified By: *[Signature]*



THERMAL EXPANSION FACTOR

The dimensions of a differential producing flow meter are affected by the operating temperature, requiring a Thermal Expansion Factor (F_a) to be included in the calculations. The calculation requires the temperature at which the meter dimensions were measured be known. If this information is not available, an ambient temperature of 68° F is assumed. The Thermal Expansion Factor is calculated according to the American Society of Mechanical Engineers Standard ASME MFC-3M-1989, Equation 17 (pg 11).

$$F_a = 1 + \frac{2}{1 - \beta^4} (\alpha_{PE} - \beta^4_{meas} \alpha_p)(t - t_{meas})$$

where β = ratio of throat diameter to pipe diameter, dimensionless
 α_{PE} = thermal expansion factor of primary element, (in./in./°F)
 α_p = thermal expansion factor of pipe, (in./in./°F)
 t = temperature of flowing fluid, °F
 t_{meas} = temperature of measurements, °F

Thermal expansion factors, α , excerpted from MFC-3M-1989, are listed in the Table below for six typically used materials at three temperatures. Linear interpolation is used to determine the coefficients at flowing temperature.

$$\text{Mean Coefficient of Thermal Expansion} = \frac{A}{10^6} \text{ (in./in./°F)}$$

| Material | Coef. | -50 °F | 70 °F | 200 °F |
|----------------------------|-------|--------|-------|--------|
| Bronze 4-10 | A | 9.15 | 9.57 | 10.03 |
| 300 Series Stainless Steel | A | 8.90 | 9.11 | 9.34 |
| Monel | A | 7.15 | 7.48 | 7.84 |
| .2 to 1.1% C Steel | A | 5.80 | 6.07 | 6.38 |
| 5% Chrome Moly | A | 5.45 | 5.73 | 6.04 |
| 410 to 430 Stainless Steel | A | 5.00 | 5.24 | 5.50 |



WATER DENSITY*

| Temperature | Density | Temperature | Density | Temperature | Density |
|-------------|-----------------------------------|-------------|-----------------------------------|-------------|-----------------------------------|
| Fahrenheit | lb _m / ft ³ | Fahrenheit | lb _m / ft ³ | Fahrenheit | lb _m / ft ³ |
| 32 | 62.4179 | 62 | 62.3549 | 92 | 62.0903 |
| 33 | 62.4201 | 63 | 62.3489 | 93 | 62.0788 |
| 34 | 62.4220 | 64 | 62.3427 | 94 | 62.0671 |
| 35 | 62.4235 | 65 | 62.3363 | 95 | 62.0552 |
| 36 | 62.4246 | 66 | 62.3296 | 96 | 62.0432 |
| 37 | 62.4255 | 67 | 62.3228 | 97 | 62.0311 |
| 38 | 62.4260 | 68 | 62.3157 | 98 | 62.0188 |
| 39 | 62.4262 | 69 | 62.3084 | 99 | 62.0063 |
| 40 | 62.4261 | 70 | 62.3010 | 100 | 61.9937 |
| 41 | 62.4257 | 71 | 62.2933 | 101 | 61.9810 |
| 42 | 62.4250 | 72 | 62.2855 | 102 | 61.9681 |
| 43 | 62.4240 | 73 | 62.2774 | 103 | 61.9551 |
| 44 | 62.4227 | 74 | 62.2692 | 104 | 61.9419 |
| 45 | 62.4211 | 75 | 62.2608 | 105 | 61.9286 |
| 46 | 62.4193 | 76 | 62.2522 | 106 | 61.9151 |
| 47 | 62.4171 | 77 | 62.2434 | 107 | 61.9015 |
| 48 | 62.4147 | 78 | 62.2344 | 108 | 61.8878 |
| 49 | 62.4121 | 79 | 62.2252 | 109 | 61.8739 |
| 50 | 62.4092 | 80 | 62.2159 | 110 | 61.8599 |
| 51 | 62.4060 | 81 | 62.2063 | 111 | 61.8458 |
| 52 | 62.4025 | 82 | 62.1966 | 112 | 61.8315 |
| 53 | 62.3988 | 83 | 62.1868 | 113 | 61.8172 |
| 54 | 62.3949 | 84 | 62.1767 | 114 | 61.8027 |
| 55 | 62.3907 | 85 | 62.1665 | 115 | 61.7880 |
| 56 | 62.3863 | 86 | 62.1561 | 116 | 61.7733 |
| 57 | 62.3816 | 87 | 62.1456 | 117 | 61.7584 |
| 58 | 62.3768 | 88 | 62.1348 | 118 | 61.7434 |
| 59 | 62.3716 | 89 | 62.1239 | 119 | 61.7284 |
| 60 | 62.3663 | 90 | 62.1129 | 120 | 61.7132 |
| 61 | 62.3607 | 91 | 62.1017 | 121 | 61.6978 |

* Distilled water values used in all calculation